

ARROW POWER SERVICES

Mfrs. of : OnLine UPS, Solar UPS / Invertors & Servo Stabilizer
 #17, 1st Cross, Sonnappa Layout, Kereguddadahalli, Chickbanavara Post,
 Bangalore - 560 090 Ph : 080-65353100, 23253180, GSM :98450 79931,99450 79931
 email :arrowpowercontrols@yahoo.co.in web : www.arrowups.in.

No: 1764

Date : 30/06/13

OEM : UPS, INVERTOR, SOLAR PRODUCTS & BATTERY

INSTALLATION, SERVICE, SITE INSPECTION REPORT



Customer Name & Address : M/S SURANA COLLEGE NR SOUTH END CIRCLE Jaynagar Bangalore	Engineer's Name	Pavan Kumar S. U.N.
	Model	/
	Sl. No.	/
	Capacity	
	Battery	
	Unit Status	<input checked="" type="checkbox"/> Warranty <input type="checkbox"/> AMC <input type="checkbox"/> Out of Warranty

Problem Reported by Customer:

Engineer Report	Remarks
① 1KWATT Solar Power Plant & 150AH Battery's (2no) with sine wave UPS is installed.	① UPS & Battery's, Solar Power Plant is working fine.
② (10 no) of Solar Street Light's with 75 watts Solar PV, 80AH Battery's & 15 watts LED Light's is installed.	② (10 no) Solar Street Light's is working fine.
③ UPS Voltage is 230VAC	③ 600W wiring is working is fine.

Input Voltage	230 VAC	Input Current	
Output Voltage	230 VAC	Output Current	
DC Voltage	24VDC	Chr Current	12A
Earth Voltage			

Customer Remarks

Customer Seal & Signature  For **ARROW POWER SERVICES**
 24/7/13
 Pavan Kumar S. U.N.
 Engineer Signature



